Northwestern

Fire Prevention

Environmental Health and Safety

Table of Contents

I. Purpose 2
II. Scope 2
III. Responsibilities 2
IV. Compressed Gas Storage 3
V. Events and Catering 3
VI. Extension Cords and Power Strips 3
VII. Fire Control Equipment 4
VIII. Flammable Liquids 4
IX. Indoor Fireplaces 5
X. Open Flames and Heat Sources 5
XI. Outdoor Fire Pits 5
XII. Outdoor Grilling 5
XIII. Portable Generators 6
XIV. Rechargeable Battery-Powered Equipment 6
XV. Small Electrical Appliances and Equipment 6
XVI. Smoking 7
XVII. Space Heaters 7
XVIII. Storage of Combustible Materials 7
XIX. Tents 7
XX. Regulatory Authority and Related Information 8
XXI. Contact 8

iii. Remove all trash and refuse from worksites daily.
iv. Ensure any deficiencies identified by Northwestern or other authority having jurisdiction (e.g., city, OSHA) are corrected in a timely manner.
v. Not permitted to impair any fire or life safety system.

IV. Compressed Gas Storage

A. Storage of liquefied petroleum gas cylinders is prohibited in Northwestern-owned buildings.
B. Store compressed gas cylinders away from vehicular traffic, excessive heat, and electrical circuits.
C. Keep oxygen cylinders at least 20 feet from fuel gas cylinders or combustible materials, or by a noncombustible barrier at least 5 feet high having a fire-resistance rating of at least one-half hour.
D. Secure cylinders upright to prevent them from falling with a chain or securing to a cart.
E. Compressed gas cylinders, containers, and tank valves must be protected from physical damage by means of protective caps, collars, or similar devices.

V. Events and Catering

A. Schools, departments, and units hosting an event must ensure all general safety precautions in this sc1.3 (afe)7.9 (t)-3 (y)-4.5 ( )]TJ-0. (ne4T.w(-0.2047831.)]TJ0.6g)2.6 fsllTJ-0. (n0al)10.6 ((t)-0

B. Industrial/commercial grade equipment, power tools, and other high-current devices may not be plugged into power strips or extension cords, unless they are designated and approved with a NRTL mark for industrial/commercial use. The use of household extension cords (two-prong) and non-multi-plug adapters is prohibited.
C. Extension cords and power strips must be plugged into a wall outlet and may not be plugged into another extension cord or power strip (i.e., daisy chaining).
D. Extension cords may never be used in place of permanent wiring, may only be used for a temporary period of up to 90 days, and must be unplugged when not in use.
E. Extension cords and power strips that have a ground pin may only be plugged into grounded outlets. Devices that have a ground pin may only be plugged into extension cords and power strips that accept ground pins. Do not remove the ground pin from the plug of the device, extension cord, or power strip.
F. Ensure extension cords do not have cuts, nicks, or exposed wiring, and must be immediately removed from service if found.
G. Ensure cords are not running under carpeting or under doorways, or in any other manner that may cause damage to the cords.

VII. Fire Control Equipment

A.

All Northwestern buildings have a fire detection and alarm system. If there is smoke or heat from a fire, it will notify emergency response of the fire alarm. Oncw 18.1 (il.3 (a)-3ƀDC 0.306f c)-4(

IX. Indoor Fireplaces

A. Use fireplaces only as intended, which includes using screens.
B. Ensure flues are open prior to use, and closed once the fire is completely out and no longer hot.
C. Carbon monoxide detectors should be located near the fireplace.
D. Never leave a fireplace unattended while in use.
E. Do not put anything into the fire other than what it was intended for (e.g., wood).
F. For gas fireplaces, ensure gas valve keys are kept secured when not in use and gas is off when done.
G.

XVI. Smoking

Smoking, including the use of electronic cigarettes and vaping, is prohibited in Northwestern-owned buildings and within 25 feet of building entrances, as well as in designated outdoor facilities and where posted.

XVII. Space Heaters

Space heaters are prohibited in all Northwestern-owned spaces. In the event of temperature-related emergencies, space heaters may be used temporarily. Departments must obtain approval from Facilities Operations and EHS prior to purchasing or operating a space heater. If the department has received approval to use a space heater, they must meet the following requirements:

A. Use only electric space heaters with water/oil fluid-enclosed heating elements or ceramic-covered heating elements that provide radiant heat.
B. Space heaters must be kept three feet from combustible materials (e.g., waste baskets, furniture, coat racks, drapery, and other upholstered materials).
C. Space heaters cannot be placed in areas where flammable or explosive vapors may be potentially found.
D. Space heaters mu7 11.815 0. Tc 0 Tw 11.